WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 78466
Permit No.
Basin 90

NOTICE OF INTENT NO. 42475

1. OWNER Kingsbury GID
MAILING ADDRESS P.O. Box 2220
Stateline, NV 89449

ADDRESS AT WELL LOCATION Peale well-397 Sherwood Drive,
Stateline

2. LOCATION SE 1/4 SE 1/4 Sec. 23 T 13N N/S R 18E E Douglas County
PERMIT NO. 17782 (Issued by Water Resources) | Cert. #5798 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other _____

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Did not perf well - well				
had holes in upper				
casing. Set trimme pipe				
and pumped 4-1/2 yds				
neat cement. Cement down				
22 ft. from top.				
Proceeded to mix 10 bags				
of neat cement and				
cemented to within 3 ft.				
of the top of well.				

Date started 10/11/99 , 19__
Date completed 10/11/99 , 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 190 Feet Depth Cased _____ Feet

HOLE DIAMETER (BIT SIZE)
From To
_____ Inches _____ Feet _____ Feet
_____ Inches _____ Feet _____ Feet
_____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10				

Perforations:
Type perforation _____
Size perforation _____
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal _____
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From _____ feet to _____ feet

9. WATER LEVEL
Static water level surface feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Humboldt Drilling & Pump Co., Inc. (Contractor)
Address 4675 W. Winnemucca Blvd (Contractor)
Winnemucca, Nevada 89445
Nevada contractor's license number issued by the State Contractor's Board 015234
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1713
Signed [signature] (By driller performing actual drilling on-site or contractor)
Date 10/19/99