WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

**PRINT OR TYPE ONLY**
**DO NOT WRITE ON BACK**

**STATE OF NEVADA**
# DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 78497
Permit No.
Basin 42

NOTICE OF INTENT NO. 4445

1. OWNER ROBERT WINTER
MAILING ADDRESS P.O. BOX 238
WEST POINT, CA 95255

ADDRESS AT WELL LOCATION APPROX 35 MILES EAST OF ELKO & APPROX 5 MILES NORTH OF I-80

2. LOCATION NE 1/4 NE 1/4 Sec. 9 T 37N N/S R 59E E ELKO County
PERMIT NO. (Issued by Water Resources) 007-34D-002 (Parcel No.) TRACT OF LAND (Subdivision Name)

3. **WORK PERFORMED**
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. **PROPOSED USE**
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. **WELL TYPE**
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. **LITHOLOGIC LOG**

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Perforate from 50-420 with knife perforator | | | | |
| Pump Abandonite from 420 to 20 feet | | | | |
| Pump cement from 0-20 feet | | | | |
| Material used: | | | | |
| 16 Bags of abandonite mixed with 640 gallons of water | | | | |
| 4 Bags of cement mixed with 28 gallons of water | | | | |

Date started 9/3/99 , 19__
Date completed 9/3/99 , 19__

7. **WELL TEST DATA**
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. **WELL CONSTRUCTION**
Depth Drilled ____ Feet Depth Cased 420 Feet

**HOLE DIAMETER (BIT SIZE)**

| | From | To |
|---|---|---|
| Inches | Feet | Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

**CASING SCHEDULE**

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 13 | .188 | +1 | 420 |
| | | | | |

**Perforations:**
Type perforation KNIFE CUT
Size perforation 1X1/4
From 50 feet to 420 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From ____ feet to ____ feet

9. **WATER LEVEL**
Static water level 180 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. **DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name HACKWORTH DRILLING, INC (Contractor)
Address P.O.BOX 850 (Contractor)
ELKO,NV 89803
Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1689
Signed [signature] (By driller performing actual drilling on-site or contractor)
Date 9/14/99

USE ADDITIONAL SHEETS IF NECESSARY