WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 68499
Permit No.
Basin 84

NOTICE OF INTENT NO. 34401

1. OWNER D Debra Ginotti
MAILING ADDRESS P.O.Box 7433
South Lake Tahoe, Ca. 96158

ADDRESS AT WELL LOCATION Aniversery Road 6205
Reno, Nv. Dalomino V. Unit 3 10-2-0-1

2. LOCATION ne ¼ ne ¼ Sec. 10 T. 22n N/S R. 20 E. Washoe County
PERMIT NO. 5921 (Issued by Water Resources) 076-130-25 (Parcel No.) Parcel Map # 80 lot 2 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand & gravel		0	15	15
brown decomposed granite		15	80	65
blue decomposed granite		80	120	40
black & white granite	x	120	320	200
fractured and water bearing from 200'-240'				

RECEIVED 97 AUG -6 AM 11:05 STATE ENGINEERS OFFICE

Date started 6-25-97, 19
Date completed 7-1-97, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
10		1

8. WELL CONSTRUCTION
Depth Drilled 320 Feet Depth Cased 320 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10.625 Inches	0 Feet	60 Feet
10 Inches	60 Feet	320 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	2+	320

Perforations:
Type perforation down hole perferator
Size perforation .125
From 200 feet to 280 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured

Seal Type:
☐ Neat Cement
☒ Cement Grout
☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 320 feet

9. WATER LEVEL
Static water level 55 feet below land surface
Artesian flow no G.P.M. P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Points West Drilling (Contractor)
Address P.O. Box 178 (Contractor)
West Point, Cal. 95255

Nevada contractor's license number issued by the State Contractor's Board 39825
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1974

Signed Jimmy L Delys
By driller performing actual drilling on site or contractor
Date 7-4-97

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627