WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 78506
Permit No.
Basin 44

NOTICE OF INTENT NO. 41843

1. OWNER PX RANCH
MAILING ADDRESS HC 31 BOX 142-B
ELKO, NV 89801

ADDRESS AT WELL LOCATION PX RANCH - APPROXIMATELY 45 MILES NORTH OF ELKO

2. LOCATION SW 1/4 SE 1/4 Sec. 10 T 42N N/S R 54E E ELKO County
PERMIT NO. (Issued by Water Resources) 005-590-010 (Parcel No.) TRACT OF LAND (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOPSOIL		0	2	2
BROWN CLAY		2	6	4
GREY & WHITE CLAY &		6		
GRAVEL			80	74
GRAVEL & SAND	X	80	140	60

RECEIVED 99 SEP -8 AM 1:29 STATE ENGINEER'S OFFICE

Date started 7/27/99 , 19__
Date completed 7/27/99 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
35		4

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	140	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	+1	140

Perforations:
Type perforation MILLSLOT
Size perforation 3/16 X 3
From 120 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100
Placement Method: [ ] Pumped [X] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 100 feet to 140 feet

9. WATER LEVEL
Static water level 77 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name HACKWORTH DRILLING, INC (Contractor)
Address P.O.BOX 850 (Contractor)
ELKO,NV 89803
Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1689
Signed David Hackworth (By driller performing actual drilling on-site or contractor)
Date 8/2/99

USE ADDITIONAL SHEETS IF NECESSARY