WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 78516
Permit No.
Basin 50

NOTICE OF INTENT NO. 42431

1. OWNER PAT LAUGHLIN
MAILING ADDRESS HC 34-371-7
ELKO, NV 89801

ADDRESS AT WELL LOCATION OFF MT. CITY HWY NORTH OF ELKO

2. LOCATION NW 1/4 NW 1/4 Sec. 14 T 35N N/S R 54E E ELKO County
PERMIT NO. 65003 (Issued by Water Resources) 005-520-024 (Parcel No.) TRACT OF LAND (Subdivision Name)

3. **WORK PERFORMED**
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. **PROPOSED USE**
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [X] Stock

5. **WELL TYPE**
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. **LITHOLOGIC LOG**

Material	Water Strata	From	To	Thickness
TOPSOIL		0	3	3
BOULDERS		3	12	9
SILTSTONE		12	120	108
SANDSTONE & SOME CLAY	X	120	400	280

RECEIVED 99 SEP -8 AM 1:29 STATE ENGINEER'S OFFICE

Date started 7/29/99, 19__
Date completed 7/30/99, 19__

7. **WELL TEST DATA**
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
10		5

8. **WELL CONSTRUCTION**
Depth Drilled 400 Feet Depth Cased 400 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8 Inches		0 Feet	400 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	+1	400

Perforations:
Type perforation MILLSLOT
Size perforation 3/16 X 3
From 380 feet to 400 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100
Placement Method: [ ] Pumped [X] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 100 feet to 400 feet

9. **WATER LEVEL**
Static water level 180 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. **DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name HACKWORTH DRILLING, INC (Contractor)
Address P.O.BOX 850 (Contractor)
ELKO,NV 89803
Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1689
Signed David Hackworth (By driller performing actual drilling on-site or contractor)
Date 8/4/99

USE ADDITIONAL SHEETS IF NECESSARY