WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 78520
Permit No.
Basin 45

NOTICE OF INTENT NO. 42455

1. OWNER ANN JAYO
MAILING ADDRESS 488 RABBIT EARS DRIVE
SPRING CREEK, NV 89815

ADDRESS AT WELL LOCATION 488 RABBIT EARS DRIVE

2. LOCATION NW 1/4 NE 1/4 Sec. 26 T 33N N/S R 57E E ELKO County
PERMIT NO. (Issued by Water Resources) 023-022-007 (Parcel No.) PLEASANT VALLEY ESTATES (Subdivision Name)

3. **WORK PERFORMED**
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. **PROPOSED USE**
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. **WELL TYPE**
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. **LITHOLOGIC LOG**

Material	Water Strata	From	To	Thickness
TOPSOIL		0	2	2
BROWN CLAY		2	5	3
BRAVEL & SAND		5	80	75
SAND		80	130	50
SAND & GRAVEL	145	130	165	35

RECEIVED 99 NOV -3 AM 10:52 STATE ENGINEER'S OFFICE

Date started 9/30/99, 19__
Date completed 9/30/99, 19__

7. **WELL TEST DATA**
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15		2

8. **WELL CONSTRUCTION**
Depth Drilled 165 Feet Depth Cased 165 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	165	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	+1	165

Perforations:
Type perforation MILLSLOT
Size perforation 3/16 X 3
From 145 feet to 165 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100
Placement Method: [ ] Pumped [X] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 100 feet to 165 feet

9. **WATER LEVEL**
Static water level 103 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. **DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name HACKWORTH DRILLING, INC (Contractor)
Address P.O.BOX 850 (Contractor)
ELKO,NV 89803
Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1689
Signed (By driller performing actual drilling on-site or contractor)
Date 9/29/99

USE ADDITIONAL SHEETS IF NECESSARY