WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 78526
Permit No.
Basin 187B
NOTICE OF INTENT NO. 23957

1. OWNER Round Mountain Gold Corporation
MAILING ADDRESS P.O. Box 480
Round Mountain, NV 89045
ADDRESS AT WELL LOCATION Round Mountain Gold Mine

2. LOCATION NE ¼ SE ¼ Sec. 24 T. 10N N/S R. 43 E. Nye County
PERMIT NO. 65178T (Issued by Water Resources) Parcel No. Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Granite dominated Allu		0'	385'	385'
Volcanic dom. Alluvium		385'	420'	35'
Granite dom. Alluvium		420'	760'	340'
Volcanic dom. Alluvium		760"	825'	65'
Mixed volc's&Lake seds		825'	1,065'	240'
Volcanics		1,065'	1,200'	135'

RECEIVED 00 JAN 12 AM 11:22 STATE ENGINEER'S OFFICE

Date started 9-29, 1999
Date completed 10-29, 1999

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
plugged by 16331		

8. WELL CONSTRUCTION
Depth Drilled 1,206 Feet Depth Cased 1,200 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
28 Inches		0 Feet	40 Feet
20 Inches		40 Feet	1,206 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
24	63.7	.250	0	40
12.75	33.6	.250	0	532
12.75	33.5	.250	832/1200	1015/1200

Perforations:
Type perforation Johnson Wire wrap
Size perforation .080
From 1190 feet to 1014 feet
From 831 feet to 531 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 55' feet to 1200 feet

9. WATER LEVEL
Static water level 488 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name LAYNE CHRISTENSEN (Contractor)
Address 12030 E. RIGGS RD. (Contractor)
CHANDLER, AZ 85249
Nevada contractor's license number issued by the State Contractor's Board 0019101
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1683
Signed C R Fitzgibbon (By driller performing actual drilling on site or contractor)
Date 1-6-00

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627