WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 78562
Permit No.
Basin 90

NOTICE OF INTENT NO. 29267

1. OWNER Roundhill Pines Resort Inc.
MAILING ADDRESS 300 Highway 50 Roundhill Nev
ADDRESS AT WELL LOCATION 300 Highway 50 Roundhill Nev

2. LOCATION NW ¼ SW ¼ Sec. 15 T. 13 N/S R. 18 E. Douglas County
PERMIT NO. ~~29267~~ 05-230-120
Issued by Water Resources | Parcel No. | Subdivision Name

MW-744

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG MW # 3

Material	Water Strata	From	To	Thickness
OBSERVED well	16			
TO BE IN GOOD				
CONDITION, PULLED				
COVER, OVERDRILLED				
CASING to 29 feet				
AND PRESSURE GROUTED				
to SURFACE.				

RECEIVED 98 DEC 23 AM 11:19 STATE ENGINEER'S OFFICE

Date started 10/22, 19 99
Date completed 10/22, 19 99

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
	N/A	

8. WELL CONSTRUCTION
Depth Drilled 29 Feet Depth Cased 29 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	Feet	26 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4	Factory	020	0	29

Perforations:
Type perforation Factory
Size perforation 020
From 29 feet to 14 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 29
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 0 feet to 29 feet

9. WATER LEVEL
Static water level 15 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature COLD °F Quality N/A

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Andreesen Exploration Drilling (Contractor)
Address 1635 Belford Road (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 345 25
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M 2139
Signed (Driller performing actual drilling on site or contractor)
Date 11/11/98

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627