WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 78569
Permit No.
Basin

NOTICE OF INTENT NO. [illegible]15

1. OWNER Frank Woolsey
MAILING ADDRESS 2161 W Williams Ave
Fallon, NV 89406

ADDRESS AT WELL LOCATION
4000 Hawk Drive, Fallon, NV 89406

2. LOCATION NE 1/4 NE 1/4 Sec. 28 T 19N N/S R 28E E Churchill County
PERMIT NO. (Issued by Water Resources) | 008-281-14 (Parcel No.) | Mills (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Sand		0	8	8
Brown Clay		8	18	10
Brown Sand		18	39	21
Gray Clay		39	49	10
Gray Sand		49	55	6
Brown Sand	X	55	67	12

RECEIVED 97 JUL -7 AM 11:10 STATE ENGINEER'S OFFICE

Date started 11/13/96, 19__
Date completed 11/14/96, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 67 Feet Depth Cased 67 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	67	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	67

Perforations:
Type perforation Mill Cut
Size perforation 1/8
From 64 feet to 67 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 67 feet

9. WATER LEVEL
Static water level 9 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc. (Contractor)
Address P.O. Box 1265 (Contractor)
Fallon, NV 89407-1265

Nevada contractor's license number issued by the State Contractor's Board 29064

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753

Signed [signature] (By driller performing actual drilling on-site or contractor)
Date 3-19-97