


STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **39812**

1. OWNER **Washoe County School District**
 MAILING ADDRESS **1850 Kleppe Lane**
Reno, NV 89506

ADDRESS AT WELL LOCATION **1850 Kleppe Lane**
Reno, Nevada 89506

2. LOCATION **NW 1/4 SW 1/4 Sec. 11 T 19N** N/S R **20E** E **Washoe** County

PERMIT NO. **28045** Issued by Water Resources **034-164-02** Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Remove pump from well, measure total depth 120 bail well to depth of 126, well would immediately fill in with sandy formation. Perforate 4 rows from 47 to 74 with mills knife perforator. Install trimie pipe and pump approx 8008 lbs of neat cement. to surface to abandon, weld on steel plate on casing T.D. 130				

8. WELL CONSTRUCTION
 Depth Drilled **130** Feet Depth Cased **130** Feet

HOLE DIAMETER (BIT SIZE)
 From To
8 Inches **0** Feet **130** Feet
 Inches Feet Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8		12 ga	+1-1/2	130

Perforations:
 Type perforation **Factory cut/mills knife**
 Size perforation **1/8 x 3 / 1/4 x 3**

From	feet to		feet
From	126	feet to	74 feet
From	74	feet to	47 feet
From		feet to	feet
From		feet to	feet

Surface Seal: Yes No Seal Type:
 Depth of Seal **47** Neat Cement
 Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level **6** feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **A.S.A.P. Pump & Well Service** Contractor
 Address **P.O. Box 60130** Contractor
Reno, Nevada
 Nevada contractor's license number issued by the State Contractor's Board **35387-A**
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1509**
 Signed *[Signature]*
 by driller performing actual drilling on-site or contractor
 Date **10/6/99**

Date started **9/29/99**, 19____
 Date completed **9/30/99**, 19____

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	