

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **19622**

1. OWNER **Paula Schilling** ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS **1441 W. Huckleberry** **1441 W. Huckleberry**  
**Pahrump, NV 89048**

2. LOCATION **NW 1/4 NW 1/4 Sec. 29 T 20S N/S R 53E E Nye** County  
 PERMIT NO. **39-032-13** **Calvada**  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<b>brown clay</b>		<b>0</b>	<b>6</b>	<b>6</b>
<b>grey clay</b>		<b>6</b>	<b>12</b>	<b>6</b>
<b>light green clay</b>		<b>12</b>	<b>22</b>	<b>10</b>
<b>See next line</b>		<b>22</b>	<b>33</b>	<b>11</b>
<b>grey clay with caleche strings</b>				
<b>light green clay</b>		<b>33</b>	<b>58</b>	<b>25</b>
<b>grey caleche</b>	<b>x</b>	<b>58</b>	<b>68</b>	<b>10</b>
<b>See next line</b>	<b>x</b>	<b>68</b>	<b>82</b>	<b>14</b>
<b>grey clay with caleche strings</b>				
<b>See next line</b>	<b>x</b>	<b>82</b>	<b>140</b>	<b>58</b>
<b>brown clay with caleche strings</b>				

8. WELL CONSTRUCTION  
 Depth Drilled **140** Feet Depth Cased **140+1** Feet

HOLE DIAMETER (BIT SIZE)  
 From To  
**11** Inches **0** Feet **140** Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<b>6 5/8</b>	<b>3.7</b>	<b>.280</b>	<b>0</b>	<b>140</b>

Perforations:  
 Type perforation **sawcut**  
 Size perforation **.188**

From **115** feet to **140** feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal **50**  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout


Gravel Packed:  Yes  No  
 From **50** feet to **140** feet

9. WATER LEVEL  
 Static water level **62** feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature **cool** °F Quality **good**

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name **Strickland Construction Co., Inc.** Contractor  
 Address **2301 Winery Road, Suite 2** Contractor  
**Pahrump, NV 89048**

Nevada contractor's license number issued by the State Contractor's Board **40277**  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **2086**

Signed *[Signature]*  
 Date **1-29-00**



Date started **1/8/00**, 19\_\_\_\_  
 Date completed **1/8/00**, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift Draw Down (Feet Below Static)		Time (Hours)
	G.P.M.		

