WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 78598
Permit No.
Basin 162

NOTICE OF INTENT NO. 19612

1. OWNER Brad Colgrove
MAILING ADDRESS 1890 E. Santovito
Pahrump, NV 89048

ADDRESS AT WELL LOCATION
1890 E. Santovito

2. LOCATION SE 1/4 SE 1/4 Sec. 14 T 21S N/S R 53E E Nye County
PERMIT NO. Issued by Water Resources
44-751-04 Parcel No.
Mesa Oeste Estates Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
brown loam		0	9	9
brown clay		9	16	7
light brown clayx	x	16	92	56
grey clay	x	92	106	14
See next line	x	106	180	74
grey clay with caleche stringers				

Date started 1/5/00, 19__
Date completed 1/5/00, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 180 Feet Depth Cased 180+1 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
11 Inches	0 Feet	180 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	0	180

Perforations:
Type perforation sawcut
Size perforation .188
From 155 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 180 feet

9. WATER LEVEL
Static water level 62 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Strickland Construction Co., Inc. Contractor
Address 2301 Winery Road, Suite 2 Contractor
Pahrump, NV 89048
Nevada contractor's license number issued by the State Contractor's Board 40277
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2086
Signed By driller performing actual drilling on-site or contractor
Date 1.29.00

DCNR/DWR Received FEB 4 2000 LAS VEGAS OFFICE