WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 78627
Permit No.
Basin 212

NOTICE OF INTENT NO. 18556

1. OWNER Ms. Stella Sobchik
MAILING ADDRESS 18 Sawgrass Court
Las Vegas, NV 89113

ADDRESS AT WELL LOCATION 917 Fremont St., Las Vegas, NV

2. LOCATION NE 1/4 SE 1/4 Sec. 34 T T20S N/S R R61E E Clark County
PERMIT NO. (Issued by Water Resources) | Parcel No. 139-34-612-076 | Subdivision Name MW-1

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphalt/Fill		0	2	2
Gravelly sand		2	8	6
Caliche		8	10	2
Silty sand		10	15	5
Sandy clay		15	18	3
Gravelly clay		18	20	2

DCNR/DWR Received FEB 11 2000 LAS VEGAS OFFICE

Date started 10/12/1999 , 19__
Date completed 10/12/1999 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 20 Feet Depth Cased 20 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
6	Inches	0	Feet	20	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	0.64	0.154	0	20

Perforations:
Type perforation Factory slot
Size perforation 0.020
From 10 feet to 20 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 0-6'/6-8' bentonite
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 8 feet to 20 feet

9. WATER LEVEL
Static water level 11.82 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Don Wilson c/o Converse Consultants (Contractor)
Address 731 Pilot Road, Suite H (Contractor)
Las Vegas, NV 89119
Nevada contractor's license number issued by the State Contractor's Board 48947
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1589
Signed Don Wilson (By driller performing actual drilling on-site or contractor)
Date 2/11/2000

I

USE ADDITIONAL SHEETS IF NECESSARY