

STATE OF NEVADA
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY
 Log No. 78653
 Permit No. _____
 Basin 212

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 18530

1. OWNER AGRA
 MAILING ADDRESS 4205 W. Tompkins Avenue, Suite 5
Las Vegas, NV 89108
 ADDRESS AT WELL LOCATION 707 South 1st Street,
Las Vegas, NV

2. LOCATION SW 1/4 SE 1/4 Sec. 34 T T20S N/S R R61E E Clark County
 PERMIT NO. 139-34-310-002 Parcel No. B-1 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE Domestic Municipal/Industrial Irrigation Monitor Test Stock
 5. WELL TYPE Cable Rotary RVC Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clayey sand		0	1	1
Poorly graded sand		1	4	3
Silty lean clay		4	5.5	1.5
Caliche		5.5	6	.5
Silty lean clay		6	9	3
Caliche		9	11.5	2.5
Silty lean clay		11.5	12.5	1
Caliche		12.5	13.5	1
Silty lean clay		13.5	14.8	1.3
Caliche		14.8	17	2.2
Silty lean clay		17	17.5	.5
Caliche		17.5	20	2.5

8. WELL CONSTRUCTION
 Depth Drilled 20 Feet Depth Cased 20 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 To 20 Feet
8 Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	0.64	0.154	0	20


Perforations:
 Type perforation Factory slot
 Size perforation 0.020
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No
 Depth of Seal 0-6'6-8' bentonite
 Placement Method: Pumped Poured
 Seal Type: Neat Cement Cement Grout Concrete Grout
 Gravel Packed: Yes No
 From 8 feet to 20 feet

9. WATER LEVEL
 Static water level 7.4 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Thomas High c/o Converse Consultants Contractor
 Address 731 Pilot Road, Suite H Contractor
Las Vegas, NV 89119
 Nevada contractor's license number issued by the State Contractor's Board 48947
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1869
 Signed Thomas High
 By driller performing actual drilling on-site or contractor
 Date 2/11/2000



Date started 8/23/1999, 19____
 Date completed 8/23/1999, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			