WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 78683
Permit No.
Basin 212

NOTICE OF INTENT NO. 18539

1. OWNER Nevada Department of Transportation
MAILING ADDRESS 1263 South Stewart Street
Carson City, NV 89712

ADDRESS AT WELL LOCATION 1325 North Main Street,
Las Vegas, NV 89101

2. LOCATION SW 1/4 NE 1/4 Sec. 27 T T20S N/S R R61E E Clark County
PERMIT NO. (Issued by Water Resources) | 002-020-006 (Parcel No.) | MW-11 (Subdivision Name)

3. **WORK PERFORMED**
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. **PROPOSED USE**
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. **WELL TYPE**
[ ] Cable [ ] Rotary [ ] RVC
[ ] Air [X] Other Auger

6. **LITHOLOGIC LOG**

Material	Water Strata	From	To	Thickness
Asphalt/fill		0	1.5	1.5
Sandy silt		1.5	4.5	3
Sandy clay		4.5	13	8.5
Sandy silt		13	25	12

Date started 11/21/1999 , 19__
Date completed 11/21/1999 , 19__

7. **WELL TEST DATA**
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. **WELL CONSTRUCTION**
Depth Drilled 25 Feet Depth Cased 25 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8	Inches	0	Feet	25	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	0.64	0.154	0	25

Perforations:
Type perforation Factory slot
Size perforation 0.020
From 5 feet to 25 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 0-1'/1-3' bentonite
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 3 feet to 25 feet

9. **WATER LEVEL**
Static water level 12.0 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. **DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Thomas High c/o Converse Consultants
Contractor
Address 731 Pilot Road, Suite H
Contractor
Las Vegas, NV 89119
Nevada contractor's license number issued by the State Contractor's Board 48947
Nevada driller's license number issued by the Division of Water Resources, the ~~on-site driller~~ M-1069
Signed
By driller performing actual drilling on site or contractor
Date 2/11/2000

USE ADDITIONAL SHEETS IF NECESSARY