WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. ~~99-69~~ 78686 baseline
Permit No. 78687 Plug
Basin 72A

NOTICE OF INTENT NO. 43182

1. OWNER Tom Miller
MAILING ADDRESS 1215 Goldstone, Reno, NV 89506
ADDRESS AT WELL LOCATION 1215 Goldstone, Reno, NV 89506

2. LOCATION SW ¼ SE ¼ Sec. 30 T. 22N N/S R. 19 E. Washoe County
PERMIT NO. (Issued by Water Resources) 079-352-20 (Parcel No.) Red Rock Estates #32 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other plug

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Firm silty sand		0	308	308
DG, some gravels, some light brown clay, dry		308	582	274
Gray clay, DG & sand		582	700	118

NOTE: This well bore is dry. Backfilled to 55', sealed with concrete grout in 10" bore to surface. Invoice #182833 American Redy Mix.

RECEIVED 99 DEC 23 AM 10:44 STATE ENGINEERS OFFICE

Date started October 26, 1999
Date completed November 15, 1999

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 700 Feet Depth Cased 0 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
10 5/8	0	55
8 1/2	55	700

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
		NONE		

Perforations:
Type perforation NONE
Size perforation
From NONE feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 55
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 0 feet below land surface
Artesian flow – G.P.M. – P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Aqua Drilling & Well Service, Inc. (Contractor)
Address 675 Edison Way (Contractor)
Reno, NV 89502
Nevada contractor's license number issued by the State Contractor's Board 15291
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1132 & 1981
Signed Roger [illegible] (By driller performing actual drilling on site or contractor)
Date December 15, 1999

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627