

OFFICE USE ONLY
 Log No. ~~7870~~ 78688
 Permit No. 99-924
 Basin
 NOTICE OF INTENT NO. 43182

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Tom Miller ADDRESS AT WELL LOCATION 1215 Goldstone
 MAILING ADDRESS 1215 Goldstone Reno, NV 89506
 2. LOCATION SW 1/4 SE 1/4 Sec. 30 T 22N N/S R. 19 E Washoe County
 PERMIT NO. 079-352-20 Red Rock Estates # 32
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Dirt, DG & silt		0	30	30
Rock		30	31	1
Greenish DG & Silt with scattered rock		30	408	378
Brown silt and DG		408	536	128
Rock fragments	x	536	537	1
Fine Rock & Brown Clay		537	596	59
Heavy brown clay & fine rock		596	676	80
Fine rock, no clay	x	676	692	16
Heavy brown clay		692	696	4

8. WELL CONSTRUCTION
 Depth Drilled 696 Feet Depth Cased 696 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 5/8 Inches 0 Feet 50 Feet
8 1/2 Inches 50 Feet 696 Feet
 Inches Feet Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+2	696

Perforations: Factory
 Type perforation
 Size perforation 3/32 x 3
 From 536 feet to 556 feet
 From 656 feet to 676 feet
 From feet to feet
 From feet to feet
 From feet to feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Cement Grout
 Placement Method: Pumped Poured Concrete Grout
 Gravel Packed: Yes No
 From feet to feet

9. WATER LEVEL
 Static water level 470 feet below land surface
 Artesian flow - G.P.M. - P.S.I.
 Water temperature - °F Quality -

Date started November 15 1999
 Date completed December 16 1999

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	5		

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Aqua Drilling & Well Service, Inc. Contractor
 Address 675 Edison Way Contractor
Reno, NV 89502
 Nevada contractor's license number 15291
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 1132 & 1981
 Division of Water Resources, the on-site driller
 Signed Roger W. Thiele
 By driller performing actual drilling on site or contractor
 Date December 17, 1999