

OFFICE USE ONLY
 Log No. 78689
 Permit No. 84
 Basin 1
 NOTICE OF INTENT NO. 40304

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Dan Gettings
 MAILING ADDRESS 5700 Peak Rd Reno, NV 89510
 ADDRESS AT WELL LOCATION 5700 Peak Rd Reno, NV 89510

2. LOCATION SE 1/4 NW 1 T 22 N/S R 20 E Washoe County
 PERMIT NO. 76-241-06 Parcel No. 1-2-0-1 Subdivision Name Palumbo Unit 5
 Issued by Water Resources

3. WORK PERFORMED
 New Well Replace Recondition Domestic
 Deepen Abandon Other Municipal/Industrial

4. PROPOSED USE
 Irrigation Test Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
No additional perforation required per conversation with Tom Gallager 8/19/99, install trimie pipe to total depth pump approx 14670 pounds of neat cement to surface, cut off casing 3' below finished grade, SWL 8/21/99 460 feet.				
Abandon to 475'				
<i>Part of log # 57632</i>				
<i>Continued on next page</i>				

8. WELL CONSTRUCTION
 Depth Drilled 475 Feet Depth Cased 475 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To
_____	_____	_____
_____	_____	_____
_____	_____	_____

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.92</u>	<u>.188</u>	<u>+2</u>	<u>345</u>

Perforations:

Type perforation Factory sawed
 Size perforation 3/32 x 3

From	To
<u>325</u> feet to	<u>345</u> feet
<u>455</u> feet to	<u>475</u> feet
_____ feet to	_____ feet
_____ feet to	_____ feet
_____ feet to	_____ feet

Surface Seal: Yes No
 Depth of Seal 475
 Placement Method: Pumped Poured
 Seal Type: Neat Cement Cement Grout Concrete Grout
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 460' feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name A.S.A.P. Pump & Well Service, Inc. Contractor
 Address P.O. Box 60130 Contractor

Reno, NV 89506
 Nevada contractor's license number issued by the State Contractor's Board 35387-A

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2066

Signed [Signature]
 By driller performing actual drilling on-site or contractor
 Date 8/26/99

Date started 8/21/99, 19____
 Date completed 8/21/99, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input checked="" type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
<u>DRY</u>			