

OFFICE USE ONLY  
 Log No. 78703  
 Permit No. \_\_\_\_\_  
 Basin 162

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 19344

1. OWNER JAMES & MARY HOWES ADDRESS AT WELL LOCATION 4420 E. MARTIN AVE.  
 MAILING ADDRESS \_\_\_\_\_

2. LOCATION SE 1/4 NW 1/4 Sec. 29 T. 21-S N/S R. 54 E NYE County \_\_\_\_\_  
 PERMIT NO. 45-391-16 FOX HOLLOW Subdivision Name \_\_\_\_\_  
 Issued by Water Resources Parcel No. \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SURFACE		0	4	4
SANDY LOAM		4	10	6
BROWN CLAY/GRAVEL		10	38	28
CEMENTED GRAVEL		38	71	33
BROWN CLAY/CALICHE/ W/SANDSTONE	X	71	115	44
BROWN CLAY		115	146	31
BROWN CLAY/GRAVEL	X	146	160	14

8. WELL CONSTRUCTION  
 Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)  
 From To  
12 Inches 0 Feet 160 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet


CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	160

Perforations:  
 Type perforation TORCH CUT  
 Size perforation 1/4" WIDTH 8" LONG  
 From 120 feet to 160 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50'  Neat Cement  
 Placement Method:  Pumped  Concrete Grout  
 Poured

Gravel Packed:  Yes  No  
 From 50' feet to 160' feet



Date started FEBRUARY 7, 2000  
 Date completed FEBRUARY 7, 2000

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	4	1/4

9. WATER LEVEL  
 Static water level 66' feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name JIM PIKE WELL DRILLING, LLC Contractor  
 Address P.O. BOX 56 Contractor  
PAHRUMP, NV 89041  
 Nevada contractor's license number issued by the State Contractor's Board 17563A  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1812  
 Signed [Signature]  
 By driller performing actual drilling on site of contractor  
 Date FEBRUARY 11, 2000

