

WHITE-DIVISION OF WATER RESOURCES  
 CANARY-CLIENT'S COPY  
 PINK-WELL DRILLER'S COPY

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY  
 Log No. 78723  
 Permit No. I  
 Basin. 6  
 NOTICE OF INTENT NO. 43233

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER BARRICK GOLDSTRIKE MINES ADDRESS AT WELL LOCATION BARRICK GOLDSTRIKE MINESITE, NORTH OF CARLIN, NV  
 MAILING ADDRESS P.O. BOX 29  
ELKO, NV 89803  
 2. LOCATION SW 1/4 SE 1/4 Sec. 19 T. 36 N. S. R. 50 E EUREKA County  
 PERMIT NO. 55140 Issued by Water Resources Parcel No. N/A Subdivision Name N/A

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal  Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
GREY ROCK		0	80	80
BLACK & GREY ROCK		80	160	80
BLACK ROCK		160	180	20
BLACK & GREY ROCK		180	210	30
GREY ROCK		210	280	70
BLACK ROCK		280	350	70
GREY & WHITE ROCK		350	370	20
GREY ROCK		370	395	15
BLACK ROCK		395	420	25
GREY ROCK		420	435	15
BLACK ROCK		435	485	50
BLACK & GREY ROCK		485	500	15
GREY ROCK		500	570	70
BLACK & GEY ROCK		570	585	15
GREY ROCK		585	735	150
GREY ROCK & SAND		735	755	20
GREY ROCK		755	820	65
BLACK ROCK		820	830	10
GREY ROCK		830	855	15
BLACK ROCK		855	860	5
GREY ROCK		860	865	5
BLACK ROCK		865	875	10
GREY ROCK		875	880	5

8. WELL CONSTRUCTION  
 Depth Drilled 880 Feet Depth Cased 793 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
1.9 Inches 0 Feet 40 Feet  
12.5 Inches 40 Feet 880 Feet  
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
14	36.71	0.250	0	40
6.625	17.02	0.250	+1	793

Perforations:  
 Type perforation LOUVERED  
 Size perforation 0.125 X 2.375"  
 From 11 feet to 793 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 10'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 10 feet to 793 feet

9. WATER LEVEL  
 Static water level 642 feet below land surface  
 Artesian flow N/A G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature 68 °F Quality GOOD

Date started SEPTEMBER 29, 1999  
 Date completed OCTOBER 8, 1999

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
20	45	ONE	

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name LANG EXPLORATORY DRILLING Contractor  
 Address P.O. BOX 5279 Contractor  
ELKO, NV 89802  
 Nevada contractor's license number issued by the State Contractor's Board 0021976  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2130  
 Signed Scott Belliston  
 By driller performing actual drilling on site or contractor  
 Date SEPTEMBER 11, 1999