WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 78725
Permit No.
Basin 816

NOTICE OF INTENT NO. 39852

1. OWNER Richard & Sara Hayes
MAILING ADDRESS 511 E. 5th St.
Sun Valley, NV 89432

ADDRESS AT WELL LOCATION 900 Apple Blossom, Sun Valley, NV

2. LOCATION NE 1/4 SE 1/4 Sec. 8 T 20N N/S R 20E E Washoe County
PERMIT NO. WaCo# (Issued by Water Resources) | 508-030-32 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden		0	2	2
Broken Granite		2	18	16
Granite		18	120	102
Brown Granite		120	180	60
Granite		180	380	200
Broken Granite	x	380	420	40

Date started 11/15/1999, 19__
Date completed 11/17/1999, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30		2 hrs

8. WELL CONSTRUCTION
Depth Drilled 420 Feet Depth Cased 420 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	60	Feet
9	Inches	60	Feet	420	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+1	420

Perforations:
Type perforation Factory
Size perforation 3/32 x 3"
From 400 feet to 420 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 420 feet

9. WATER LEVEL
Static water level 340 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality Not Tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719
Signed R. Bruce MacKay (By driller performing actual drilling on-site or contractor)
Date 11/18/99

USE ADDITIONAL SHEETS IF NECESSARY