WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
# DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 78727
Permit No.
Basin 87

NOTICE OF INTENT NO. 38074

1. OWNER Clyde Porter
MAILING ADDRESS 7575 Shadow Lane
Sparks, NV 89434

ADDRESS AT WELL LOCATION 7575 Shadow Lane

2. LOCATION SW 1/4 SE 1/4 Sec. 27 T 20N N/S R 20E E Washoe County
PERMIT NO. WaCo#6476 (Issued by Water Resources) 035-310-56 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| On this date we abandoned the 6 5/8" well. We perforated from 78' to surface using a Mills Knife at four perforations at 90 degrees apart and 1 foot intervals. We pumped approximately 3.5 yards neat cement at 5.2 gallons/sack which brought the cement to 14'. We then "topped" off the top 14' with concrete groute with 3/4" rock. We cut the casing off flush with the finished floor of the pump house. During the perforating process, we hit what we believe was a liner pipe at 79'. We could not get the perforator past that point and it felt very solid. We used a tremie pipe to 146' and pumped the neat cement using a pressure grout machine. The bottom of the well was measured at 149'. | | | | |

Date started 11/17/1999, 19__
Date completed 11/17/1999, 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| Inches | Inches | Feet | Feet |
| Inches | Inches | Feet | Feet |
| Inches | Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 12.92 | .188 | 0 | ? |
| 5"? | | | 78 | 149 |
| | | | | |

Perforations:
Type perforation Mills Knife
Size perforation
From 78 feet to Surface feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 36 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719
Signed R. Bruce MacKay (By driller performing actual drilling on-site or contractor)
Date 11/18/99

USE ADDITIONAL SHEETS IF NECESSARY