

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

office use only
Log No. 78732
Permit No. 100
Basin 100
NOTICE OF INTENT NO 42377
1000 Little Valley Rd

1. OWNER
MAILING ADDRESS Gerald & Jean Robtoy
1090 Chisholm Trl
Reno NV

ADDRESS AT WELL LOCATION

2. Location NE 1/4 SW 1/4 Sec 17 T 21N R 18E Washoe County
PERMIT NO. PARCEL NO. 87-401-13 SUBDIVISION NAME

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|-------------------|--------------|------|-----|-----------|
| Rock & gray clay. | | 0 | 197 | 197 |
| Granite. | | 197 | 248 | 51 |
| Broken granite. | 250 | 248 | 265 | 17 |

8. WELL CONSTRUCTION
 Depth Drilled 265 feet Depth Cased 265 feet
 HOLE DIAMETER (BIT SIZE)
 From To
 10 5/8 inches 0 feet 50 feet
 8 3/4 inches 50 feet 265 feet
 inches feet feet
 CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| 6 5/8 | 12.94 | 188 | +1 1/2 | 265 |

 Perforations:

| Type Perforation | Factory |
|------------------|--------------|
| Size perforation | 3/32 x 3" |
| From 245 feet to | 265 feet |
| From | feet to feet |
| From | feet to feet |
| From | feet to feet |
| From | feet to feet |
| From | feet to feet |

 Surface Seal YES No Seal Type:
 Depth of Seal 50 feet Neat Cement
 Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 265 feet

991110 22 2112:56
 STATE ENGINEER'S OFFICE

9. WATER LEVEL
 Static water level 195 feet below land surface
 Artesian flow 0 GPM 0 P.S.I.
 Water Temperature cold Degrees F Quality

Date started 12-1 -99
 Date completed 12-4 -99

7. WELL TEST DATA

| TEST METHOD: | Bailer | Pump | x | Air Lift |
|--------------|-------------------------------|--------------|---|----------|
| G.P.M. | Draw Down (Feet Below Static) | Time (hours) | | |
| 13 | 35 | | | |
| 30 | 65 | | | |

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **McKay Drilling, Inc.**
 2290 Pioneer Drive
 Reno, NV 89509

NV Contractors No. 14170
 NV Driller's Lic (on site) 2121

Signed *Steve McKay*

By driller performing actual drilling on site or contractor
 Date 12-10 -99