

Log No. 78733
 Permit No. _____
 Basin 92A

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 42821

1. OWNER LARRY LIKES J&L BUILDERS ADDRESS AT WELL LOCATION 10770 Red Rock Road
 MAILING ADDRESS 10900 Red Rock Road 10770 Red Rock Road
Reno, Nevada 89506 Reno, Nevada 89506
 2. LOCATION NW 1/4 NW 1/4 Sec 25 T 21N N/S R 18 E Washoe County
 PERMIT NO. 086-163-09 Silver Knolls
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Brown clay		1	6	5
Brown sandy clay		6	18	12
Brown medium sand		18	21	3
Brown sandy clay		21	46	25
Brown clay		46	57	11
Gray sandy clay		57	130	73
Gray sand	X	130	141	11
Gray sandy clay		141	158	17
Soft zone (NO WATER)		158	159	1
Gray sandy clay		159	165	6
Soft zone	X	165	171	6
Brown sandy clay		171	183	12
Soft zone	X	183	190	7
Brown sandy clay		190	300	10

8. WELL CONSTRUCTION
 Depth Drilled 200 Feet Depth Cased 200 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 Inches 0 Feet 50 Feet
8 5/8 Inches 50 Feet 200 Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	200

Perforations: factory sawed slot
 Type perforation _____
 Size perforation 3/32 x 3 x 5 around
 From 135 feet to 155 feet
 From 175 feet to 195 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 feet Neat Cement
 Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From 50 feet to 200 feet

Date started 12-16-99, 19____
 Date completed 12-17-99, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	20+		

9. WATER LEVEL
 Static water level 69 feet below land surface
 Artesian flow _____ G.P.M. 20+ P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WAYNE DRILLING, INC. Contractor
 Address P.O. BOX 12370 Contractor
RENO, NEVADA 89510
 Nevada contractor's license number issued by the State Contractor's Board 0022549
 Nevada driller's license number issued by the Division of Water Resources the on-site driller 923
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date December 22, 1999