249

pz99-18

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 78742
Permit No.
Basin 61

NOTICE OF INTENT NO. 43222

1. OWNER BARRICK GOLDSTRIKE MINES
MAILING ADDRESS P.O. BOX 29
ELKO, NV 89803

ADDRESS AT WELL LOCATION BARRICK GOLDSTRIKE MINESITE, NORTH OF CARLIN, NV.

2. LOCATION NE ¼ SW ¼ Sec. 19 T. 36 N/S R. 50 E. EUREKA County
PERMIT NO. N/A (Issued by Water Resources) N/A (Parcel No.) N/A (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BLACK ROCK		0	100	100
BLACK & GREY ROCK		100	145	45
BLACK ROCK		145	370	225
BLACK & GREY ROCK		370	380	10
BLACK ROCK		380	445	65
BLACK & GREY ROCK		445	450	5
BLACK ROCK		450	605	155
BLACK & GREY ROCK		605	610	5
BLACK ROCK		610	650	40
CONSTRUCTION DETAIL:				
CEMENT		0	50	50
HOLE PLUG		50	610	560
GRAVEL		610	650	40

Date started AUGUST 11, 1999
Date completed AUGUST 16, 1999

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
TRACE		

8. WELL CONSTRUCTION
Depth Drilled 650 Feet Depth Cased 640 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
14.75 Inches		0 Feet	30 Feet
6.25 Inches		30 Feet	650 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10.750	28.04	0.250	+3	30
2.375	3.65	0.154	+1	240

Perforations:
Type perforation SLOTTED
Size perforation 0.125" X 3"
From 620 feet to 640 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 610 feet to 650 feet

9. WATER LEVEL
Static water level 266 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature WARM °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name LANG EXPLORATORY DRILLING (Contractor)
Address P.O. BOX 5279 (Contractor)
ELKO, NV 89802
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2085
Signed Daniel Kohlman (By driller performing actual drilling on site or contractor)
Date AUGUST 16, 1999

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627

B.ST.L