WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 78747
Permit No.
Basin 107

NOTICE OF INTENT NO. 41680

1. OWNER Alton & Susan Anker
MAILING ADDRESS

ADDRESS AT WELL LOCATION 170 Olson Ranch Rd
Smith Valley

2. LOCATION ¼ ¼ Sec. 16 T. 11 N/S R. 24 E. Lyon County
PERMIT NO. Issued by Water Resources | 10-441-28 Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand gravel		1	26	
Clay		26	73	
Sand		73	94	
Clay Gravel		94	144	
Gravels		144	171	
Gravels, Sands		171	193	
Clay	213	193	213	
Clay Gravels	260	213	260	
Sand Clay		260	274	
~~Clay~~ Gravels Sand	274	274	289	
Gravels	295	289	295	
Clay		295	300'	

Date started 9/28/99, 19
Date completed 10/1/99, 19

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
125+	(12'-13')	1 3/4 hrs

8. WELL CONSTRUCTION
Depth Drilled 300' Feet Depth Cased 300' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12 3/4 Inches	1 Feet	300' Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	13	1.88	1	20'
8 5/8	PVC Sch 80		20	300'

Perforations:
Type perforation Machine Perf
Size perforation 3/16 x 6 x 5 rows
From 275 feet to 298 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100'
Placement Method: ☒ Pumped ☐ Poured

Seal Type:
☐ Neat Cement
☒ Cement Grout
☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 200' feet to 300' feet

9. WATER LEVEL
Static water level 30' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature C °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Pearce Drill Inc
Contractor
Address P.O. 999
Contractor
SS NV 89429

Nevada contractor's license number issued by the State Contractor's Board 0031841

~~Nevada driller~~'s license number issued by the Division of Water Resources, the on-site driller 1876

Signed [signature]
By driller performing actual drilling on site or contractor

Date 10/1/99

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627