

Log No. 78749
 Permit No. _____
 Basin 105

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 43061

1. OWNER AL Shankle Const. ADDRESS AT WELL LOCATION 311 Jones
 MAILING ADDRESS 224B Meridian Blvd Minden NV
 2. LOCATION S.W. 1/4 S.E. 1/4 Sec. 15 T. 12 N S R. 19 E Douglas County
 PERMIT NO. 19-140-05 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
DG		0	34	34
DG & Boulders		34	41	7
DG	✓	41	65	24
DG & Boulders		65	76	11
DG		76	105	29
DG & Boulders		105	115	10
DG		115	326	211
DG & CLAY		326	337	11
Hard fractured Granite	✓	337	410	73
DG	✓	410	430	20
Hard Granite		430	440	10

8. WELL CONSTRUCTION
 Depth Drilled 440 Feet Depth Cased 440 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
12 3/4 Inches 0 Feet 380 Feet
7 7/8 Inches 380 Feet 440 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 3/8</u>	<u>17</u>	<u>.108</u>	<u>42</u>	<u>380</u>
<u>6 5/8</u>	<u>13</u>	<u>.108</u>	<u>380</u>	<u>440</u>

Perforations:
 Type perforation Factory Milled
 Size perforation 10 x 2 1/2 in.
 From 320 feet to 380 feet
 From 400 feet to 440 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 100 feet to 380 feet

9. WATER LEVEL
 Static water level: 227 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 60.1 °F Quality Good

Date started 12-9 1999
 Date completed 1-13 2000

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>75</u>		<u>3 hrs</u>
<u>Air</u>			

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Eddco Exploration Inc Contractor
 Address 7780 Curry Rd Contractor
Fallon, NV 89406
 Nevada contractor's license number issued by the State Contractor's Board: 27673A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 1586
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 1-13-00

RECEIVED
 00 JAN 21 AM 11:01
 DIVISION OF WATER RESOURCES