

OFFICE USE ONLY  
 Log No. 78754  
 Permit No. 105  
 Basin  
 NOTICE OF INTENT NO. 42152

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Bentley Nevada ADDRESS AT WELL LOCATION  
 MAILING ADDRESS 1617 WATER ST. MINDEN NV 89423 1631 BENTLEY PARKWAY GAV NV  
 2. LOCATION NE 1/4 SW 1/4 Sec 27 T. 13 N. S. R. 20' E. DOUGLAS County  
 PERMIT NO. 65234-T 23 530 19 NA Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Clay Gravels		0	25	
Sand Gravels	L	25	50	
Sand Gravels	L	50	90	
Brown Clay		90	110	
Sand Gravels	L	110	131	
Brown Clay		131	148	
Sand and Gravel	L	148	157	
Brown Clay		157	160	
Gravels and Clay		160	180	
Sand Gravel Sand	L	180	220	
Brown Clay		220	240	
Brown Clay		240	260	
Large Gravels	L	240	260	
Brown Clay		260	300	

8. WELL CONSTRUCTION  
 Depth Drilled 300' Feet Depth Cased 300' Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 1 1/4 Inches To 300' Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>-</u>	<u>1.88</u>	<u>13</u>	<u>180</u>
			<u>220</u>	<u>240</u>
			<u>260</u>	<u>300</u>

Perforations:  
 Type perforation Wire Wrap Screen  
 Size perforation 50 .050  
 From 180 feet to 220 feet  
 From 240 feet to 260 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal 100  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 300 feet to 100' feet

RECEIVED  
 99 OCT -5 PM 12:37  
 STATE ENGINEERS OFFICE

Date started 9-21, 1999  
 Date completed 9-27-, 1999

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Airlift</u>	<u>1500</u>	<u>270</u>	<u>5</u>

9. WATER LEVEL  
 Static water level 36' feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality NA

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name NU Drilling Inc. Contractor  
 Address 75 Leavers Cr. Red Carson City Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 13697-A  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1790  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 9-30-99