WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 78756
Permit No. 85
Basin 85

NOTICE OF INTENT NO. [redacted]

1. OWNER Joseph Williams
MAILING ADDRESS 1148 O'Callaghan Ct. Sparks, Nv 89432
ADDRESS AT WELL LOCATION 1000 Los Arboles

2. LOCATION SE ¼ SE ¼ Sec. 16 T. 21 N R. 21 E. Washoe County
PERMIT NO. (Issued by Water Resources) 076-310-53 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
hole drilled by McKay Drilling				
well drillers Report enclosed				
24' concrete grout			0	
			100	
			200	
Native DG Material			300	
24' To 1050			400	
			500	
			600	
			700	
			800	
			900	
			1000	
1050-1060-Hole Plug			1100	
3/8 cut chip (Bentonite)			1200	
Native D.G. Material			1300	
1200-1210 Hole Plug			1400	
Native DG Material			1500	
1540-1550 Hole Plug			1600	T.D.
Native DG Material				
witnessed by Ken Stine - Washoe County heath inspector				

Date started 2-12-00
Date completed 2-12-00

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
N/A	Dry hole	

8. WELL CONSTRUCTION
Depth Drilled 1600 Feet Depth Cased 1050 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
11 Inches		0 Feet	52 Feet
8 3/4 Inches		52 Feet	1050 Feet
6 1/8 Inches		1050 Feet	1500 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.94	.188	+1½	1050

Perforations:
Type perforation Factory
Size perforation 1/8 x 3
From 1030 feet to 1050 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 52
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 52 feet to 1050 feet

9. WATER LEVEL
Static water level Dry hole feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Waytek Drilling (Contractor)
Address 2220 Stowe Dr (Contractor)
Reno Nv 89511
Nevada contractor's license number issued by the State Contractor's Board 0145217
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1374
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 2-14-00

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627