WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 78759
Permit No. [illegible]
Basin [illegible]

NOTICE OF INTENT NO. 30874

1. OWNER ALBERT & VICTORIA GONZALES
MAILING ADDRESS 4817 ELESTE LN. N.LAS VEGAS NV. 89030
ADDRESS AT WELL LOCATION Lot 6 Block 8 Preston town site

2. LOCATION SE ¼ SE ¼ Sec 12 T 12 N/S R 61 E White Pine County
PERMIT NO. N/A (Issued by Water Resources) 13-024-01 (Parcel No.) Preston town site (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	2	
gravel clay con.		2	4	
gravel conglomerate		4	7	
clay gravel Con.		7	35	
gravel		35	37	
clay conglomerate		37	78	
Sand	water	78	79	
clay Con.		79	88	
Sand	water	88	90	
clay Con.		90	101	
Sand	water	101	102	
clay Con.		102	110	
Sand gravel	water	110	112	
Clay		112	118	
Sand gravel		118	120	

RECEIVED 00 FEB 16 AM 11:35 WATER RESOURCES

Date started Jan 31, 2000
Date completed Feb 10, 2000

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	6	1hr

8. WELL CONSTRUCTION
Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	71 Feet
8 Inches	71 Feet	120 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	4	120

Perforations:
Type perforation Mill
Size perforation 1/8 x 2.5" x 6 row
From feet to feet
From 74 feet to 94 feet
From 100 feet to 120 feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 71'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 71 feet to 120 feet

9. WATER LEVEL
Static water level 71 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Orvan R Maynard (Contractor)
Address 439 N 100W Po Box 64 Lund NV 89317 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 047226
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1556
Signed Orvan Maynard (By driller performing actual drilling on site or contractor)
Date Feb 12-00

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627