

OFFICE USE ONLY  
 Log No. 78764  
 Permit No. \_\_\_\_\_  
 Basin 1275

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. \_\_\_\_\_

1. OWNER ROUND MOUNTAIN GOLD CORP. ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS P.O. BOX 480 \_\_\_\_\_  
ROUND MOUNTAIN, NV 89045 \_\_\_\_\_  
 2. LOCATION SW 1/4 SW 1/4 Sec 19 T. 10 N 43 44 E NYE County  
 PERMIT NO. 59125T W387 \_\_\_\_\_  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
1. Pull pumping system.				
2. Ran Tremie pipe.				
3. Pump neat cement to above SWL (14 yards).				
4. Fill well to approx. 100' from surface with 3/8" hole plug (approx. 8 pallets).				
5. Pumped cement sand slurry to the surface (100 0').				
NO ADDITIONAL PERFORATIONS				

8. WELL CONSTRUCTION  
 Depth Drilled 1260 Feet Depth Cased 1260 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 21.5 Inches To 0 Feet 235 Feet  
15 Inches 235 Feet 1155 Feet  
14 3/4 Inches 1155 Feet 1260 Feet  
 CASING SCHEDULE  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16			0	235
10 3/4			+3	1260

 Perforations:  
 Type perforation Shutter  
 Size perforation 1/8 x 3  
 From 915 feet to 1195 feet  
 From 1235 feet to 1355 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes,  No Seal Type:  
 Depth of Seal 235 \_\_\_\_\_  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 7-28, 19 98  
 Date completed 7-29, 19 98

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
N/A			

9. WATER LEVEL  
 Static water level 700' feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name LAYNE CHRISTENSEN CO. Contractor  
 Address P.O. BOX 606 Contractor  
CARSON CITY, NV 89702  
 Nevada contractor's license number 0019101  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the 1564  
 Division of Water Resources, the on-site driller  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 7/29/98