

OFFICE USE ONLY
 Log No. 18770
 Permit No. 88
 Basin 88

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTEREST NO. 42862
CROSS STREET LAKE

1. OWNER MONTREUX ADDRESS AT WELL LOCATION: GENEVA AND BORDEAUX
 MAILING ADDRESS: 16475 BORDEAUX DRIVE
RENO, NV 89511

2. LOCATION: NW 1/4 SE 1/4 Sec 3 T. 17 N. S. R. 19 E. WASHOE County
 PERMIT NO. 65364 Issued by Water Resources Parcel No. 148-150-01 Subdivision Name MONTREUX

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
BROWN SAND, GREY & BLACK BOULDERS		0	20	20
BROWN SAND & GREY ROCK		20	40	20
BROWN SAND, GREY & WHITE ROCK		40	50	10
GREY ROCK		50	60	10
GREY & BROWN ROCK		60	90	30
GRANITIC SANDS & GRAVELS		90	100	10
BLACK & GREY ROCK		100	350	250
GREY VOLCANIC ROCK		350	660	310
MAROON VOLCANIC ROCK		660	710	50
MAROON & GREY ROCK		710	730	20
GREY ROCK, A LITTLE CLAY & GRAVEL		730	760	30

8. WELL CONSTRUCTION
 Depth Drilled 755 Feet Depth Cased 750 Feet

HOLE DIAMETER (BIT SIZE)

From	To
38 Inches	0 Feet 7 Feet
29 Inches	7 Feet 10.5 Feet
19 Inches	10.5 Feet 75.5 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
32	168.21	0.500	0	7
22	86.61	0.375	+1	100
14	36.71	0.250	+2	750

Perforations:
 Type perforation V-WIRE
 Size perforation 0.080"
 From 540 feet to 740 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 755 feet to SURFACE feet

9. WATER LEVEL
 Static water level: 309 feet below land surface
 Artesian flow N/A G.P.M. _____ P.S.I. _____
 Water temperature COOL °F Quality GOOD

Date started JANUARY 22, 2000
 Date completed FEBRUARY 3, 2000

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
260	21'	1/2	

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name LANG EXPLORATORY DRILLING Contractor
 Address P.O. BOX 5279 Contractor
ELKO, NV 89802
 Nevada contractor's license number issued by the State Contractor's Board: 0021976
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 2130
 Signed Scott Belliston
 By driller performing actual drilling on site or contractor
 Date FEBRUARY 4, 2000