

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 4167

1. OWNER FREHNER CONSTRUCTION ADDRESS AT WELL LOCATION COLD SPRINGS NV.
 MAILING ADDRESS 4040 FREHNER RD
LAS VEGAS, NV 89030

2. LOCATION NW 1/4 NE 1/4 Sec. 24 T 19 N/S R 37 E CHURCHILL County
 PERMIT NO. C-195 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Construction Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND AND GRAVEL		0	30	30
BROWN CLAY		30	50	20
GRAVEL AND BOULDERS		50	220	170
CLAY AND GRAVEL		220	270	50
SAND AND GRAVEL		285	385	100
BROWN CLAY		385	395	10
SAND AND GRAVEL	XX	395	440	45

8. WELL CONSTRUCTION
 Depth Drilled 440 Feet Depth Cased 440 Feet

HOLE DIAMETER (BIT SIZE)
 From 15 Inches To 0 Feet 440 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8</u>	<u>7.17</u>	<u>.188</u>	<u>0</u>	<u>40</u>
<u>8 5/8</u>		<u>.188</u>	<u>40</u>	<u>440</u>

Perforations:
 Type perforation SAW CUT
 Size perforation 1/8

From _____	300	feet to _____	440	feet
From _____		feet to _____		feet
From _____		feet to _____		feet
From _____		feet to _____		feet
From _____		feet to _____		feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100 Neat Cement
 Placement Method: Pumped Concrete Grout
 Poured

Gravel Packed: Yes No
 From 120 feet to 440 feet

9. WATER LEVEL
 Static water level 150 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ *F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Parsons Drilling, Inc. Contractor
 Address P.O. Box 1264 Contractor
Fallon, Nv. 89407
 Nevada contractor's license number issued by the State Contractor's Board 29064
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753
 Signed W. Parsons
 By driller performing actual drilling on-site or contractor
 Date 7/26/99

Date started 05/21/1999, 19____
 Date completed 05/27/1999, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			