

STATE OF NEVADA
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY
 Log No. 78786
 Permit No. 101
 Basin
 NOTICE OF INTENT NO. **36813**

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Ken Davis ADDRESS AT WELL LOCATION 8870 Helens Way Fallon
 MAILING ADDRESS 8870 Helens Way Nv. 89406
Fallon, NV 89406
 2. LOCATION NW 1/4 NW 1/4 Sec. 2 T 17 N/S R 28 E Churchill County
 PERMIT NO. 006-031-71 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED New Well Replace Recondition Deepen Abandon Other
 4. PROPOSED USE Domestic Irrigation Test Municipal/Industrial Monitor Stock
 5. WELL TYPE Cable Rotary RVC Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown sand		0	3	3
Brown clay		3	9	6
Brown sand		9	14	5
brown clay		14	23	9
Brown sand		23	27	4
Green sand		27	33	6
Black clay		33	57	24
Black sand	xx	57	65	8

RECEIVED
 00 FEB 14 PM 12:04
 STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 65 Feet Depth Cased 65 Feet
 HOLE DIAMETER (BIT SIZE)
10 inches From 0 Feet To 65 Feet
 _____ inches _____ Feet _____ Feet
 _____ inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	.188	0	10
6 pvc	3.92	.258	10	65

Perforations:
 Type perforation saw cut
 Size perforation 1/8
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement
 Depth of Seal 50 Cement Grout
 Placement Method: Pumped Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 65 feet

9. WATER LEVEL
 Static water level 1 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality unknown

Date started 01/24/2000 2000 .19
 Date completed 01/24/2000 2000 .19

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>40</u>		<u>1hr</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Parsons Drilling, Inc. Contractor
 Address P.O. Box 1264 Contractor
Fallon Nv. 89407
 Nevada contractor's license number issued by the State Contractor's Board 29064
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753
 Signed Wayne Parsons
 By driller performing actual drilling on-site or contractor
 Date 01/26/2000