VD-97-1

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 78794
Permit No.
Basin 061

NOTICE OF INTENT NO. 26238

1. OWNER BARRICK GOLDSTRIKE
MAILING ADDRESS P.O. BOX 29
ELKO, NV 89801

ADDRESS AT WELL LOCATION
BARRICK GOLDSTRIKE MINE

2. LOCATION NE ¼ NE ¼ Sec. 30 T 36 (N)S R 50 E EUREKA County
PERMIT NO. 61407 (Issued by Water Resources) | N/A (Parcel No.) | N/A (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal (Industrial) ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
GRAVEL		0	75	75
GRAVEL & CLAY		75	420	340
BLACK ROCK		420	470	50
RED/BROWN ROCK		470	515	45
GREY ROCK/SOME CLAY		515	530	15
BLACK ROCK & GRAVEL		530	595	60
GREY ROCK & GRAVEL		595	620	25
BLACK ROCK & GRAVEL		620	630	10
BLACK CLAY/SOME GRAVEL		630	645	15
GREY ROCK & GRAVEL		645	655	10
GREY ROCK		655	750	95

Date started FEBRUARY 13, 19 97
Date completed FEBRUARY 18, 19 97

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	130	1

8. WELL CONSTRUCTION
Depth Drilled 750 Feet Depth Cased 740 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12-1/2 Inches	0 Feet	20 Feet
9-7/8 Inches	20 Feet	750 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
12	33.38	.250	0	20
6	17.02	.250	+1-1/2	60

Perforations:
Type perforation LOUVERD
Size perforation 1/8
From 600 feet to 740 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 740 feet

9. WATER LEVEL
Static water level 491.3 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name LANG EXPLORATORY DRILLING (Contractor)
Address 2286 WEST 1500 SOUTH (Contractor)
SALT LAKE CITY, UTAH 84104

Nevada contractor's license number issued by the State Contractor's Board 0021976

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2000

Signed BILL EDDY Bill Eddy
By driller performing actual drilling on site or contractor

Date FEBRUARY 18, 1997

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627