

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY

Log No. 78804

Permit No. \_\_\_\_\_

Basin 69

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 42487

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

1. OWNER Scott & Stephanie Huseboe ADDRESS AT WELL LOCATION 85 First East Street - Paradise Valley  
 MAILING ADDRESS P.O. Box 72 Paradise Valley, NV 89426

2. LOCATION 1/4 1/4 Sec. 25 T 42N N/S R 39E E Humboldt County  
 PERMIT NO. 04-373-12 block L  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
top soil		0	5	
large gravel		5	9	4
sandy clay		9	20	11
gravel/sand/clay		20	55	35
large gravel		55	67	12
sand & clay/gravel streaks		67	95	28
coarse sand/gravel	x	95	132	37
clay		132	140	8

8. WELL CONSTRUCTION

Depth Drilled 140 Feet Depth Cased 130 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To
<u>11</u>	<u>0</u>	<u>50</u>
<u>9-7/8</u>	<u>50</u>	<u>140</u>

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6-5/8</u>		<u>.188</u>	<u>+2</u>	<u>130</u>

Perforations:  
 Type perforation single row mill slot  
 Size perforation 1/8 x 3

From	To
<u>110</u> feet to	<u>130</u> feet
_____ feet to	_____ feet
_____ feet to	_____ feet
_____ feet to	_____ feet
_____ feet to	_____ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal 104

Placement Method:  Pumped  Poured

Gravel Packed:  Yes  No  
 From 104 feet to 140 feet

Date started 10/26/99, 19\_\_  
 Date completed 10/27/99, 19\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>30</u>		<u>2 hrs</u>

9. WATER LEVEL  
 Static water level 12 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Humboldt Drilling & Pump Co., Inc. Contractor  
 Address 4675 W. Winnemucca Blvd Contractor  
Winnemucca, Nevada 89445  
 Nevada contractor's license number issued by the State Contractor's Board 015234  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2019  
 Signed [Signature]  
 By driller performing actual drilling on-site or contractor  
 Date 11/9/99

RECEIVED  
 99 NOV 10 AM 11:20  
 STATE ENGINEER'S OFFICE