WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 78818
Permit No.
Basin 105

NOTICE OF INTENT NO. 42243

1. OWNER NATE LEISING
MAILING ADDRESS 626 Hwy 88
GARDNERVILLE NV 89410

ADDRESS AT WELL LOCATION OPEN FIELD @ Hyw. 88 4mi+- W. OF 395

2. LOCATION NE SE 1/4 NW SW 1/4 Sec. 30 19 T. 12 N/S R. 20 E. DOUGLAS County
PERMIT NO. ~~52030~~ 61468 Issued by Water Resources 61469 Parcel No. 19.260 440 Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND, GRAVEL,	5'	0	304	
COBBLES WITH	304'			
SOME CLAY LAYERS				

RECEIVED
00 JAN 13 AM 8:37
STATE ENGINEERS OFFICE

Date started 9-15, 1999
Date completed 9-29, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
350-400		6 HOURS

8. WELL CONSTRUCTION
Depth Drilled 304 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
14.75 Inches		0 Feet	100 Feet
12.25 Inches		100 Feet	304 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8"		.188	+2	240

Perforations:
Type perforation SLOT / WIRE WRAP / MECHANICAL PERFERATED
Size perforation 3/32" / 3/32"
From 100 feet to 240 feet MECHAN PERF
From feet to feet
From 240 feet to 280 feet SLOT
From feet to feet
From 280 feet to 300 feet WIRE WRAP

Surface Seal: ☑ Yes ☐ No
Depth of Seal 100'
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 100 feet to 300 feet

9. WATER LEVEL
Static water level 5' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 53 °F Quality good / CLEAR

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name NEVADA DRILLING INC Contractor
Address 75 LEWERS CREEK RD 89704
CARSON CITY NEVADA Contractor
Nevada contractor's license number issued by the State Contractor's Board 13697A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1902
Signed John B. Leach
By driller performing actual drilling on site or contractor
Date 12-1-99

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627