WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 28821
Permit No.
Basin 205

NOTICE OF INTENT NO. 42910

1. OWNER Douglas County Community Developement
MAILING ADDRESS P.O. Box 218
Minden, NV 89423

ADDRESS AT WELL LOCATION Along Heybourne lane
near Minden, NV.

2. LOCATION NW 1/4 NE 1/4 Sec. 5 T 13N N/S R 20E E Douglas County
PERMIT NO. 47339-47340 Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Measured static water level at 21.4'. Measured depth of well at 253.8. Bailed debris from bottom well until we had a hard bottom at 256'. Installed 252' of tremme pipe and pumped in neat cement to surface. Pumped in approximately 7 cubic yards of neat cement. Actual well volume should have only required 5.1 cubic yards.				
Original well log attached.				

Date started 12/14/99, 19__
Date completed 12/15/99, 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 260 Feet Depth Cased 260 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10"			+2	257'

Perforations:
Type perforation double slot
Size perforation 3/32 x 3
From 67 feet to 257 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 256'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 21.4' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Carson Pump (Contractor)
Address 1401 North Roop St. (Contractor)
Carson City, NV. 89701
Nevada contractor's license number issued by the State Contractor's Board 39920
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1482
Signed [signature] (By driller performing actual drilling on-site or contractor)
Date 1/3/00

USE ADDITIONAL SHEETS IF NECESSARY

Plugging of log # 28741