WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 78837
Permit No.
Basin 101

NOTICE OF INTENT NO. 439

1. OWNER CHRH Limited
MAILING ADDRESS 436 Barmbel Dr
Fernley, NV 89408

ADDRESS AT WELL LOCATION 11464 Fulkerson Rd
Fallon Nv. 89406

2. LOCATION SE 1/4 NW 1/4 Sec. 14 T 19 N/S R 27 E Churchill County
PERMIT NO. _____ Issued by Water Resources | 07-111-41 Parcel No. | _____ Subdivision Name

3. **WORK PERFORMED**
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other _____

4. **PROPOSED USE**
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. **WELL TYPE**
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other _____

6. **LITHOLOGIC LOG**

Material	Water Strata	From	To	Thickness
Brown sand		0	18	18
Brown Clay		18	23	5
Brown Sand		23	40	17
Brown Clay		40	70	30
Brown Sand	xx	70	90	20

Date started 01/23/~~1900~~ 2000, 19__
Date completed 01/23/~~1900~~ 2000, 19__

7. **WELL TEST DATA**

TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
40		1 hr

8. **WELL CONSTRUCTION**

Depth Drilled 90 Feet Depth Cased 90 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	90	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	.188	0	10
6 pvc	3.92	.258	10	90

Perforations:
Type perforation saw cut
Size perforation 1/8
From 85 feet to 90 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 90 feet

9. **WATER LEVEL**

Static water level 50 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature cool °F Quality Unknown

10. **DRILLER'S CERTIFICATION**

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc.
Contractor

Address P.O. Box 1264
Contractor

Fallon Nv. 89407

Nevada contractor's license number issued by the State Contractor's Board 29064

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753

Signed Wayne Parsons
By driller performing actual drilling on-site or contractor

Date 01/26/2000

USE ADDITIONAL SHEETS IF NECESSARY