WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 78837
Permit No.
Basin 101

NOTICE OF INTENT NO. 36812

1. OWNER Ron Evans
MAILING ADDRESS 2995 Lewis Ln
Fallon, NV 89406

ADDRESS AT WELL LOCATION 640 Hunter Park Way
Fallon Nv. 89406

2. LOCATION SW 1/4 SW 1/4 Sec. 19 T 19 N/S R 29 E Churchill County
PERMIT NO. (Issued by Water Resources) | Parcel No. 008-314-16 | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Clay		0	30	30
Brown Sand		30	35	5
Gray Clay		35	45	10
Gray Sand		45	55	10
Gray Clay		55	70	15
Gray Sand		70	75	5
Brown Sand	xx	75	110	35

Date started 01/06/1900 2000, 19__
Date completed 01/06/1900 2000, 19__

7. WELL TEST DATA

TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15		1hr

8. WELL CONSTRUCTION
Depth Drilled 110 Feet Depth Cased 110 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	110	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	.188	0	10
6 pvc	3.92	.258	10	110

Perforations:
Type perforation saw cut
Size perforation 1/8
From 107 feet to 110 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 100 feet to 110 feet

9. WATER LEVEL
Static water level 9'11 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc. (Contractor)
Address P.O. Box 1264 (Contractor)
Fallon Nv. 89407
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753
Signed Wayne Parsons (By driller performing actual drilling on-site or contractor)
Date 01/26/2000

USE ADDITIONAL SHEETS IF NECESSARY