


PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 3789



1. OWNER Sam Huffman ADDRESS AT WELL LOCATION _____
MAILING ADDRESS 1651 Lahontan Winnemucca, NV 89445

2. LOCATION SW 1/4 NW 1/4 Sec. 3 T 35N N/S R 38E E Humboldt County
PERMIT NO. 10-671-13 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil		0	1	
cobbles & gravel		1	51	50
coarse gravel/sand		51	59	8
sm. gravel/sand		59	67	8
gravel/sand/cobbles		67	80	13
cobbles		80	110	30
gravel/sand		110	125	15
cobbles		125	170	45
sand/gravel/clay		170	178	8
cobbles/gravel/sand		178	195	17
cobbles		195	220	25
sand & gravel		220	235	15
cobbles		235	265	30
sand & gravel/clay		265	280	15
cobbles/some gravel		280	320	40
sand & gravel/clay	x	320		
stringers			375	55
hard cobbles		375	405	30

8. WELL CONSTRUCTION
Depth Drilled 405 Feet Depth Cased 400 Feet

HOLE DIAMETER (BIT SIZE)

From		To	
<u>11</u> Inches	<u>0</u> Feet	<u>100</u> Feet	
<u>9-7/8</u> Inches	<u>100</u> Feet	<u>405</u> Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6-5/8</u>		<u>.188</u>	<u>+2</u>	<u>400</u>

Perforations:
Type perforation single row mill slot
Size perforation 1/8 x 3

From	feet to	feet
	<u>320</u>	<u>380</u>

Surface Seal: Yes No Seal Type:
Depth of Seal 100 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
From 100 feet to 405 feet

Date started 1/14/00, 19____
Date completed 1/22/00, 19____

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	<input checked="" type="checkbox"/> Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>40</u>		<u>6 hrs.</u>	

9. WATER LEVEL
Static water level 120 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Humboldt Drilling & Pump Co., Inc. Contractor
Address 4675 W. Winnemucca Blvd Contractor
Winnemucca, Nevada 89445
Nevada contractor's license number issued by the State Contractor's Board 015234
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2140
Signed Sam G. Tomp
By driller performing actual drilling on-site or contractor
Date 1/24/00