WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 78860
Permit No.
Basin 89

NOTICE OF INTENT NO. 38076A

1. OWNER Maya Miller- Michael Gilbert
MAILING ADDRESS 2185 Franktown Rd.
Carson City, NV 89704

ADDRESS AT WELL LOCATION 6185 Franktown Rd.

2. LOCATION SE 1/4 SW 1/4 Sec. 16 T 16N N/S R 19E E Washoe County
PERMIT NO. WaCo#6444 (Issued by Water Resources) 55-110-33 (Parcel No.) Subdivision Name

3. WORK PERFORMED
[X] New Well [X] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [X] Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	3	3
Red Clay & Cobbles		3	60	57
DG	x	60	120	60
Frac. Granite	x	120	135	15
DG	x	135	210	75
Frac. Granite	x	210	240	30
DG	x	240	280	40
Granite	x	280	340	60
Frac. pink quartz	x	340	360	20

Date started 12/09/1999, 19__
Date completed 01/05/2000, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [X] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50	20	2 hours

8. WELL CONSTRUCTION
Depth Drilled 360 Feet Depth Cased 360 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12 1/4"	Inches	0	Feet	130	Feet
7 7/8"	Inches	130	Feet	230	Feet
6	Inches	230	Feet	360	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	22.3	.188	+1	130
6 5/8	12.92	.188	6	230
5	10.79	.188	6	360

Perforations:
Type perforation Factory
Size perforation 3/32 x 3" single row.

From	180 (5")	feet to	280 (5")	feet
From	300 (5")	feet to	320 (5")	feet
From	340 (5")	feet to	360 (5")	feet
From	210 (6")	feet to	230 (6")	feet
From	150 (6")	feet to	190 (6")	feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 130 ft.
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 6 feet to 360 feet

9. WATER LEVEL
Static water level 0 feet below land surface
Artesian flow 30 G.P.M. 15 P.S.I.
Water temperature cold °F Quality not tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719
Signed R. Bruce MacKay (By driller performing actual drilling, on-site or contractor)
Date 01/17/2000

USE ADDITIONAL SHEETS IF NECESSARY