

OFFICE USE ONLY
 Log No. 78869
 Permit No. 101
 Basin 101
 NOTICE OF INTENT NO. 40686

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Dusty Hoistman ADDRESS AT WELL LOCATION 1700 Harrigan Rd
 MAILING ADDRESS Fallon, NV
 2. LOCATION SE 1/4 SE 1/4 Sec. 31 T. 19 N/S R. 29 E Churchill County
 PERMIT NO. 007-771-13 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>sand</u>		<u>0</u>	<u>10</u>	<u>10</u>
<u>clay</u>		<u>10</u>	<u>15</u>	<u>5</u>
<u>sand</u>		<u>15</u>	<u>45</u>	<u>30</u>
<u>clay & sand</u>		<u>45</u>	<u>90</u>	<u>45</u>
<u>clay</u>		<u>90</u>	<u>110</u>	<u>20</u>
<u>sand</u>		<u>110</u>	<u>120</u>	<u>10</u>

8. WELL CONSTRUCTION
 Depth Drilled 120 Feet Depth Cased 120 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 Inches To 0 Feet 120 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>	<u>3.7</u>	<u>.280</u>	<u>0</u>	<u>120</u>

Perforations:
 Type perforation SLOTS
 Size perforation 1/8 x 3"
 From 110 feet to 120 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 100'
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 110 feet to 120 feet

9. WATER LEVEL
 Static water level 14 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality good

Date started 1-6-00
 Date completed 1-8-00

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input checked="" type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>15</u>	<u>60</u>	<u>4</u>	

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name FARRIS DRILLING Contractor
 Address P.O. Box 5305 Contractor
Fallon NV 89407
 Nevada contractor's license number 43145
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 2082
 Division of Water Resources, the on-site driller
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 2-25-00