

OFFICE USE ONLY
 Log No. 78903
 Permit No. 105
 Basin 1
 NOTICE OF INTENT NO. 26837

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Kevin Sargent
 MAILING ADDRESS Gardnerville W. 89410
 ADDRESS AT WELL LOCATION 15 1/4 Butler crt Gardnerville W. 89410

2. LOCATION NE 1/4 NE 1/4 Sec. 34 T. 13 S R. 20 E Douglas County
 PERMIT NO. 23-260-52 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Overburden</u>		<u>0</u>	<u>2</u>	<u>2</u>
<u>Brown Hard Pan Clay</u>		<u>2</u>	<u>8</u>	<u>6</u>
<u>Coarse Gravel</u>	<u>x</u>	<u>8</u>	<u>63</u>	<u>55</u>
<u>Brown Clay and Fine Sands</u>		<u>63</u>	<u>87</u>	<u>24</u>
<u>Brown Gummy Clay</u>		<u>87</u>	<u>116</u>	<u>29</u>
<u>Brown Clay</u>		<u>116</u>	<u>129</u>	<u>13</u>
<u>Fractured Sand and DG Gravel</u>	<u>XX</u>	<u>129</u>	<u>160</u>	<u>31</u>

8. WELL CONSTRUCTION
 Depth Drilled 160 Feet Depth Cased 160 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 To 160
10 3/4 Inches 0 Feet 160 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>65/8</u>	<u>13.03</u>	<u>1188</u>	<u>0</u>	<u>160</u>

Perforations:
 Type perforation Mill Slot
 Size perforation 3x3/32
 From 140 feet to 160 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 100 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 100 feet to 160 feet

Date started 12-23, 1999
 Date completed 12-24, 1999

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>25</u>	<u>45</u>	<u>3 HRS</u>

9. WATER LEVEL
 Static water level 25 feet below land surface
 Artesian flow _____ G.P.M. 35 P.S.I.
 Water temperature Cold °F Quality 40

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name _____
 Address _____
 Nevada contractor's license number issued by the State Contractor's Board 41775
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
 Signed Michael L Beck
 By driller performing actual drilling on site or contractor
 Date 12-27-99