WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 78913
Permit No. 65741-T
Basin 162

NOTICE OF INTENT NO. 19347

1. OWNER TOWN OF PAHRUMP
MAILING ADDRESS
ADDRESS AT WELL LOCATION 461 E. HARRIS FARMS RD.

2. LOCATION NE ¼ NW ¼ Sec. 22 T. 19-S N/S R. 53 E. NYE County
PERMIT NO. 65741-T (Issued by Water Resources) 29-301-05 (Parcel No.) THE COUNTRY PLACE (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SURFACE		0	4	4
SANDY LOAM		4	10	6
BROWN CLAY/GRAVEL		10	26	16
CEMENTED GRAVEL		26	68	42
BROWN CLAY/GRAVEL		68	85	17
BROWN CLAY	X	85	126	41
BROWN CLAY/GRAVEL	X	126	235	109
CEMENTED GRAVEL	X	235	260	25
BROWN CLAY		260	270	10
CEMENTED GRAVEL/ROCK		270	280	10

Date started FEBRUARY 15, 2000
Date completed FEBRUARY 15, 2000

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	4	¼

8. WELL CONSTRUCTION
Depth Drilled 280 Feet Depth Cased 280 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
12	0	280

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	280

Perforations: TORCH CUT
Type perforation
Size perforation ¼" WIDTH 8" LONG
From 240 feet to 280 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 50 feet to 280 feet

9. WATER LEVEL
Static water level 98 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name JIM PIKE WELL DRILLING, LLC. (Contractor)
Address P.O. BOX 56 (Contractor)
PAHRUMP, NV 89041
Nevada contractor's license number issued by the State Contractor's Board 17563A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1812
Signed (By driller performing actual drilling on site or contractor)
Date FEBRUARY 18, 2000

(Rev. 3-91)
USE ADDITIONAL SHEETS IF NECESSARY
(O)-627