WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 78928
Permit No. 105
Basin

NOTICE OF INTENT NO. 27995

1. OWNER Blain McGuire Construction
MAILING ADDRESS West Washoe City Carson City NV. 89702
ADDRESS AT WELL LOCATION 2624 Kayne St Minden NV. 89423

2. LOCATION SE ¼ SE ¼ Sec. 34 T. 14 N/S R. 20 E. Douglas County
PERMIT NO. Issued by Water Resources | Parcel No. 21-201-10 | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Blow Sands		0	3	3
Hard Pan Sandstone		3	6	3
Course DG Sands		6	75	69
Brown Clay		75	136	61
Brown Clay Strates and Sandy layers		136	154	18
Gummy Clay		154	163	9
Course DG Sands		163	180	17

RECEIVED 99 NOV -4 AM 9:44 STATE ENGINEER'S OFFICE

Date started 10-28, 1999
Date completed 10-29, 1999

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25+	30	3 HRS

8. WELL CONSTRUCTION
Depth Drilled 180 Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 3/4 Inches		0 Feet	180 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	180

Perforations:
Type perforation Mill Slot
Size perforation 3x 3/32
From 160 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 55
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 55 feet to 180 feet

9. WATER LEVEL
Static water level 57 feet below land surface
Artesian flow G.P.M. 25+ P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Capital City Well Drilling Contractor
Address 20 Kit Kat Drive Carson City, NV 89706 Contractor

Nevada contractor's license number issued by the State Contractor's Board 41775
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed Michael L Hack
By driller performing actual drilling on site or contractor
Date 10-29-99

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627