

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 18932  
 Permit No. 108  
 Basin 108  
 NOTICE OF INTENT NO. **43638**

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER YERINGTON PAIUTE TRIBE ADDRESS AT WELL LOCATION 115 WYE STREET  
 MAILING ADDRESS 171 CAMPBELL LANE  
YERINGTON, NV 89447  
 2. LOCATION NE 1/4 NW 1/4 Sec. 20 T 14 N/S R 25 E LYON County  
 PERMIT NO. 14-181-09 Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other **MUD**

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
COARSE SAND		0	9	
SANDY CLAY		9	14	5
COARSE SAND		14	65	51
CLAY		65	89	24
SANDY CLAY/GRAVEL		89	230	141
GRAVEL W/ LESS CLAY	X	230	250	20

8. WELL CONSTRUCTION  
 Depth Drilled 255 Feet Depth Cased 255 Feet

HOLE DIAMETER (BIT SIZE)  
 From 12 3/4 Inches To 0 Feet  
 From 0 Feet To 255 Feet  
 From \_\_\_\_\_ Inches To \_\_\_\_\_ Feet  
 From \_\_\_\_\_ Inches To \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 3/4	16.5	.25	+2	255

Perforations:  
 Type perforation **JOHNSON SCREEN**  
 Size perforation .050

From	To
230 feet	250 feet
_____ feet	_____ feet
_____ feet	_____ feet
_____ feet	_____ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 55  Neat Cement  
 Placement Method:  Pumped  Concrete Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 55 feet to 255 feet

9. WATER LEVEL  
 Static water level 36'11" feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COOL °F Quality UNTESTED

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name WELSCO CORP. Contractor  
 Address P. O. BOX 888 Contractor  
FALLON, NV 89406  
 Nevada contractor's license number issued by the State Contractor's Board 11752  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1996

Signed [Signature]  
 By driller performing actual drilling on-site or contractor  
 Date January 19, 2000

Date started Dec 20 1999  
 Date completed January 19, 2000 1900

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input checked="" type="checkbox"/> Pump <input type="checkbox"/> Air Lift	350	125	18 HR