WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
# DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 18943
Permit No.
Basin 87

NOTICE OF INTENT NO. 38081

**1.** OWNER Antonio Maruri
MAILING ADDRESS 15490 Fawn Lane
Reno, NV 89511

ADDRESS AT WELL LOCATION 15482 Fawn Lane

**2.** LOCATION SW 1/4 NW 1/4 Sec. 36 T 18N N/S R 19E E Washoe County
PERMIT NO. WaCo#6507 (Issued by Water Resources) 150-222-12 (Parcel No.) Subdivision Name

**3. WORK PERFORMED**
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

**4. PROPOSED USE**
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

**5. WELL TYPE**
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [ ] Other

**6. LITHOLOGIC LOG**

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Top soil & cobbles | | 0 | 6 | 6 |
| Sand & gravel | | 6 | 40 | 34 |
| Gravel & large cobbles | | 40 | 60 | 20 |
| Brown weathered granite | | 60 | 140 | 80 |
| Fractured Granite | x | 140 | 220 | 80 |

Date started 01/11/2000, 19__
Date completed 01/14/2000, 19__

**7. WELL TEST DATA**

TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 75 | | 1 Hr |

**8. WELL CONSTRUCTION**
Depth Drilled 220 Feet Depth Cased 220 Feet

**HOLE DIAMETER (BIT SIZE)**

| | | From | | To | |
|---|---|---|---|---|---|
| 10 5/8 | Inches | 0 | Feet | 60 | Feet |
| 9 | Inches | 60 | Feet | 220 | Feet |
| | Inches | | Feet | | Feet |

**CASING SCHEDULE**

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 12.92 | .188 | +1 | 220 |

**Perforations:**
Type perforation Factory
Size perforation 3/32 x 3"
From 200 feet to 220 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 220 feet

**9. WATER LEVEL**
Static water level 110 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality not tested

**10. DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719
Signed R. Bruce MacKay (By driller performing actual drilling on site or contractor)
Date 01/18/2000

USE ADDITIONAL SHEETS IF NECESSARY