



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 19075

1. OWNER John Dilger ADDRESS AT WELL LOCATION 1230 White St  
 MAILING ADDRESS 1230 White St Reno, NV 89048 Reno, Nevada  
 2. LOCATION SW 1/4 NE 1/4 Sec 8 T 19S N/S R 53 E Nye County Nye  
 PERMIT NO. 36-051-19 Linda Subdivision Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silt		0'	5'	5'
White clay		5'	25'	20'
brown clay		25'	40'	15'
caliche		40'	45'	5'
sandy clay		45'	65'	20'
caliche		65'	70'	5'
brown clay		70'	85'	15'
sandy clay		85'	105'	20'
caliche		105'	110'	5'
brown clay		110'	140'	30'

8. WELL CONSTRUCTION  
 Depth Drilled 140 Feet Depth Cased 140 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 12 Inches To 140 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6.625</u>	<u>4.33</u>	<u>.316</u>	<u>0</u>	<u>140</u>

Perforations:  
 Type perforation saw cut  
 Size perforation 1/8" x 3"  
 From 100 feet to 140 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50'  Neat Cement  
 Placement Method:  Pumped  Concrete Grout  
 Poured  
 Gravel Packed:  Yes  No  
 From 50' feet to 140' feet

9. WATER LEVEL  
 Static water level 45 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started Jan 23 2000  
 Date completed Jan 24 2000

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Lake Construction Co.  
 Address 4191 S. Jackie St  
Reno, Nevada 89048  
 Nevada contractor's license number 0049225  
 issued by the State Contractor's Board  
 Nevada driller's license number 2116  
 issued by the Division of Water Resources, the on-site driller  
 Signed Forest Lake  
 By driller performing actual drilling on site or contractor  
 Date Feb 7, 2000