

OFFICE USE ONLY  
 Log No. 78961  
 Permit No. \_\_\_\_\_  
 Basin. 162

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 18481

1. OWNER Bob Hoodwin ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 3031 Parkridge \_\_\_\_\_  
Pahrump, NV 3031 Parkridge  
 2. LOCATION NW 1/4 NE 1/4 Sec 36 T 20S N/S R. 53 E E County Clark  
 PERMIT NO. 41-021-01 Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_  
 Issued by Water Resources \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Soil		0	10	10
Brown Clay		10	22	12
Sand		22	25	3
Brown Clay		25	70	45
Caliche		70	73	3
Grey Clay	X	73	97	24
Brown Clay	X	97	108	11
Brown Sand	X	108	111	3
light brown clay	X	111	160	49

8. WELL CONSTRUCTION  
 Depth Drilled 160 Feet Depth Cased 160 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 12 Inches To 0 Feet 160 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>	<u>PVC</u>	<u>Sch 40</u>	<u>0</u>	<u>160</u>

Perforations:  
 Type perforation Saw Cut  
 Size perforation Saw cut 1/8 x 8  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 100 feet to 160 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Concrete Grout  
 Poured

Gravel Packed:  Yes  No  
 From 50 feet to 160 feet

9. WATER LEVEL  
 Static water level 80 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality good

Date started 1-27-00, 19\_\_\_\_  
 Date completed 2-22-00, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>30</u>	<u>5</u>	<u>1/2</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Larry Water Well Service Contractor  
 Address P.O. Box 3392 Contractor  
Pahrump, NV 89041  
 Nevada contractor's license number issued by the State Contractor's Board: 0035901  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 1916  
 Signed Larry Jenkins  
 By driller performing actual drilling on site or contractor  
 Date 2-23-00

